



TEAM TEST HOUSE
(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL RSPCB ISO 9001:2008 OHSAS 18001:2007 JDA/UDII

Office: E-55, Chitrangan Marg
C-37, Scheme, Jaipur-302001
Phone: 0141-2252430, 2271885
E-mail: info@teamtesthouse.com

Lab.: G1-584, Sitapura Industrial Area
Tonk Road JAIPUR-302022 Raj.
Ph: 94602-22039, 94602-22040
E-mail: teamtesthouse@gmail.com
E-mail: director@teamtesthouse.com

TEST REPORT

Report No. : ST/1000
Job Identification. : 8963/16-17
Date : 30-01-2017
Issued To : M/S Agribiotech Industries Limited,
SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
District-Sikar (Rajasthan)
Type of Unit : Rectified Sprit (Grain based)
Type of Sample : Stack Emission Level
Date of Sample Collection/Monitoring : 30-12-2016
Date of Sample Receipt : 02-01-2017
Date of Test : 02-01-2017 to 30-01-2017
Sample Collected By : kishan murari
Point of Collection : Boiler Stack With Multi Cyclones (12TPH)

RESULTS

S.No	Parameters	Observed Value	Testing Protocol
1	Particulate matter [mg/Nm ³]	105.23	IS 11255 (Part 1):1985 Reaffirmed 2014
2	Flue gas Temperature [* K]	391	IS 11255 (Part 1):1985 Reaffirmed 2014
3	Exit gas Velocity [m/sec]	11.86	IS 11255 :1985 (Part 3)

Notes -

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied.
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified.

Senior Analyst

Authorized Signatory
(Report No: ST/1000)



TEAM TEST HOUSE
(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL

RSPCB

ISO 9001:2008

OHSAAS 18001:2007

JDA/UDH

Office: E-65, Chitrangan Marg,
G. Scheme, Jaipur-302001
Phone: 0141-2369960, 2771865
Website: www.teamtesthouse.com

Lab: G1-504, Sitapura Industrial Area
Tonk Road, JAIPUR-302022 Raj
Ph: 94602-22030, 94602-22049
E-mail: teamtesthouse@gmail.com
E-mail: director@teamtesthouse.com

TEST REPORT

Report No. : A/2538
Job Identification. : 8958/16-17
Date : 30-01-2017
Issued To : M/S Agribiotech Industries Limited,
SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
District-Sikar (Rajasthan)
Type of Unit : Rectified Sprit (Grain based)
Type of Sample : Ambient Air Quality Monitoring
Date of Sample Collection/Monitoring : 30-12-2016
Date of Sample Receipt : 02-01-2017
Date of Test : 02-01-2017 to 30-01-2017
Sample Collected By : kishan murari
Point of Collection : Time Office Area


RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Limits as per National Ambient Air Quality Standard, 2009
1	Carbon Monoxide [microgram/m3]	260	IS 5182 (Part 10) : 1999	4000
2	Nitrogen Dioxide as NO2 [microgram/m3]	19.05	IS 5182 (Part 6) : 2006 Reaffirmed 2012	80.00
3	Particulate Matter (PM2.5) [microgram/m3]	35.84	CPCB Guidelines	60.00
4	Sulphur Dioxide [microgram/m3]	8.33	IS 5182 (Part 2) : 2001 Reaffirmed 2012	80.00
5	Particulate Matter (PM 10) [microgram/m3]	85.88	IS 5182 (Part 23)-2006 Reaffirmed 2012	100.00

Notes -

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied.
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified.


Kishan Murari
Senior Analyst


Authorized Signatory
(Report No: A/2538)



TEAM TEST HOUSE

(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL RSPCB ISO 9001:2008 OHSAS 18001:2007 JDA/UDH

Office: E-55, Chitrangan Marg
 Scheme: Jagat (302943)
 Phone: 0147-294400, 294405
 Website: www.teamtesthouse.com

Lab: G1-58A, Sitapura Industrial Area
 Tonk Road, JAIPUR 302022 Raj.
 Ph: 01472-20039, 94602-22043
 Email: teamtesthouse@gmail.com
 Web: www.teamtesthouse.com

TEST REPORT

Report No. : N/1175
 Job Identification. : 8967/16-17
 Date : 30-01-2017
 Issued To : M/S Agribiotech Industries Limited,
 SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
 District-Sikar (Rajasthan)
 Type of Unit : Rectified Sprit (Grain based)
 Type of Sample : Work zone Noise Monitoring
 Date of Sample Collection/Monitoring : 30-12-2016
 Date of Sample Receipt : 02-01-2017
 Date of Test : 02-01-2017 to 30-01-2017
 Sample Collected By : kishan murari
 Point of Collection : Administrative Building Area

RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Exposure limit for Eight hour as per Factory Act
1	Noise Level : Leq [dB(A)]	65.4	IS 9989	90.0

Notes -

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied.
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified.

Senior Analyst

Authorized Signatory
 (Report No: N/1175)



TEAM TEST HOUSE

(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL RSPCB ISO 9001:2008 OHSAS 18001:2007 JDA/UDH

Office : E-85, Chitrangan Marg
 Jaipur-302001
 Ph : 94602-20019, 94602-20049
 E-mail : teamtesthouse@gmail.com
 Website : www.teamtesthouse.com

Lab : G1-584, Sitapura Industrial Area
 Tonk Road, JAIPUR-302022 Raj
 Ph : 94602-20019, 94602-20049
 E-mail : teamtesthouse@gmail.com
 E-mail : dire_tor@teamtesthouse.com

TEST REPORT

Report No. : N/1172
 Job Identification : 8960/16-17
 Date : 30-01-2017
 Issued To : M/S Agribiotech Industries Limited,
 SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
 District-Sikar (Rajasthan)
 Type of Unit : Rectified Sprit (Grain based)
 Type of Sample : Ambient Noise Level Monitoring
 Date of Sample Collection/Monitoring : 30-12-2016
 Date of Sample Receipt : 02-01-2017
 Date of Test : 02-01-2017 to 30-01-2017
 Sample Collected By : kishan murari
 Point of Collection : Out Side D.G. Set Shed

RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Limits as per Environment protection rules, 1986
1	Noise Level (Day Time) : Leq [dB(A)]	61.5	IS 9989	75
2	Noise Level (Night Time) : Leq [dB(A)]	50.4	IS 9989	70

Notes -

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied.
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified

[Signature]
 Pradeep Kumar Yadav
 Senior Analyst

[Signature]
 Rajesh Kumar Shrivastava
 Authorized Signatory
 (Report No: N/1172)



TEAM TEST HOUSE

(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL RSPCB ISO 9001:2008 OHSAS 18001:2007 JDA/UDH

Office - E-65, Chitrangan Marg
 Utsahem, Jaipur-302001
 Phone - 0141-2359480, 2371695
 Website - www.teamtesthouse.com

Lab - G1-584, Sitapura Industrial Area
 Tonk Road, JAIPUR-302022 Raj
 Ph - 94602-22039, 94602-22040
 E-mail - teamtesthouse@gmail.com
 E-mail - director@teamtesthouse.com

TEST REPORT

Report No. : N/1173
 Job Identification : 8961/16-17
 Date : 30-01-2017
 Issued To : M/S Agribiotech Industries Limited,
 SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
 District-Sikar (Rajasthan)
 Type of Unit : Rectified Sprit (Grain based)
 Type of Sample : Ambient Noise Level Monitoring
 Date of Sample Collection/Monitoring : 30-12-2016
 Date of Sample Receipt : 02-01-2017
 Date of Test : 02-01-2017 to 30-01-2017
 Sample Collected By : kishan murari
 Point of Collection : Out Side ETP Lab

RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Limits as per Environment protection rules, 1986
1	Noise Level (Day Time) : Leq [dB(A)]	64.3	IS 9989	75
2	Noise Level (Night Time) : Leq [dB(A)]	54.2	IS 9989	70

Notes -


- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied.
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified.

[Signature]
 Rajesh Malhotra
 Senior Analyst

[Signature]
 Rajesh Malhotra
 Authorized Signatory
 (Report No: N/1173)



TEAM TEST HOUSE
(Unit of Team Institute of Science & Technology Pvt. Ltd.)



T-1736, F-2276

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL

RSPCB

ISO 9001:2008

OHSAS 18001:2007

JDA

Office - E-65, Chitrangan Marg,
C-6 Scheme, Jaipur-302021
Phone - (0141-2173533), 2771005
E-mail - www.teamtesthouse.com

Lab - G1-584, Sitapura Industrial Area
Tonk Road, JAIPUR-302022 Rq
Ph - 94602-22039, 94602-22049
E-mail - teamtesthouse@gmail.com
E-mail - teamtest@rediffmail.com

TEST REPORT

Report No. : WW/NABL/1015
 Job Identification. : 8966/16-17
 Date : 30-01-2017
 Issued To : M/S Agribiotech Industries Limited,
 SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
 District-Sikar (Rajasthan)
 Type of Unit : Rectified Sprit (Grain based)
 Type of Sample : Wastewater Sample
 Date of Sample Collection/Monitoring : 30-12-2016
 Date of Sample Receipt : 02-01-2017
 Date of Test : 02-01-2017 to 30-01-2017
 Sample Collected By : kishan murari
 Point of Collection : Treated ETP Water

RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Limits as per Environment protection rules, 1986
1	Suspended Solids [mg/l]	63	APHA.2012:2540-D	100
2	Biochemical Oxygen Demand (BOD) [mg/l]	45	APHA 2012:5210-B	100
3	Chemical Oxygen Demand (COD) [mg/l]	203.16	APHA:2012 : 5220-C	-
4	pH	7.51	APHA:2012 : 4500 H+B	5.5 - 9.0
5	Oil & Grease [mg/l]	3	APHA-2012 :5520-B	10

Notes :-

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified

[Signature]
 Senior Analyst

[Signature]
 Authorized Signatory
 (Report No: WW/NABL/1015)



TEAM TEST HOUSE

(Unit of Team Institute of Science & Technology Pvt. Ltd.)

Approved by Ministry of Environment and Forest, Government of India as Environmental Laboratory

NABL RSPCB ISO 9001:2008 OHSAS 18001:2007 JDA/UDH

Office - E-65, Chitrangan Marg
 C-14, Boree, Jaipur-302001
 Ph: 98141-2275, 9830-2771055
 www.team-testhouse.com

Lab. - G1-584, Sitapura Industrial Area
 Tonk Road, JAIPUR-302022 Raj
 Ph: 94602-22039, 94602-22049
 E-mail: teamtesthouse@gmail.com
 E-mail: director@teamtesthouse.com

TEST REPORT

Report No. : N/1171
 Job Identification. : 8959/16-17
 Date : 30-01-2017
 Issued To : M/S Agribiotech Industries Limited,
 SP-156, RIICO Industrial Area, Ajitgarh, Tehsil-Shri Madhopur,
 District-Sikar (Rajasthan)
 Type of Unit : Rectified Sprit (Grain based)
 Type of Sample : Ambient Noise Level Monitoring
 Date of Sample Collection/Monitoring : 30-12-2016
 Date of Sample Receipt : 02-01-2017
 Date of Test : 02-01-2017 to 30-01-2017
 Sample Collected By : kishan murari
 Point of Collection : Out Side Bottling Section

RESULTS

S.No	Parameters	Observed Value	Testing Protocol	Limits as per Environment protection rules, 1986
1	Noise Level (Day Time) : Leq [dB(A)]	66.2	IS 9989	75
2	Noise Level (Night Time) : Leq [dB(A)]	55.9	IS 9989	70

Notes -

- # The results listed refer only to the tested sample (s) & parameters (s). Endorsement of products is neither inferred nor implied
- # This report is not to be reproduced wholly or in part and can not be used evidence in the court of law and should not be used in any advertising media without our special permission in writing
- # The samples will be destroyed after 15 days from the date of issue of test report unless otherwise specified.

Senior Analyst

Authorized Signatory
 (Report No: N/1171)